

MOBILE COUNTY COMMISSION



COUNTY COMMISSIONERS
CONNIE HUDSON, President
RANDALL DUEITT, Commissioner
MERCERIA LUDGOOD, Commissioner
TELEPHONE (251) 574-5077

ADMINISTRATION
GLENN L. HODGE
COUNTY ADMINISTRATOR
EDDIE KERR
DEPUTY ADMINISTRATOR
TELEPHONE (251) 574-5073
FAX (251) 574-5080

MOBILE COUNTY PUBLIC WORKS

Electrical Requirements for Residential Vinyl Lined Swimming Pools

Pool Bonding Inspection

1. All sections of the metal coping of the pool must be bonded together. Either by an approved bonding jumper or by attaching each section to a #8 bare copper conductor using an approved bonding terminal with a "true" stainless steel screw. (Magnets do not attach to "true" stainless steel).
2. A #8 bare copper conductor must be connected from the coping to all metal associated with the pool i.e., ladder, diving board, hand rails, luminaires, pool slide, and any other metal such as screened rooms with metal framing and/or fences located with 5 feet of the pool.

All Connections Must Be Visible At All Times Of The Inspection

3. The #8 bare copper must then be connected to all motor housings, pool equipment control cabinets, heater housing, and "ozonators".

Pool Final Inspection

1. GFCI protection for all 15a and 20a pump motors.
2. At least one GFCI protected receptacle within 20 feet and not closer than 6 feet. The receptacle may require an in-use cover.
3. All circuit breakers identified.
4. Electrical wiring method for swimming pools shall require that an insulated equipment grounding conductor be included in the feeder to the pool panel board and any panels, equipment, luminaires, and devices connected to the panel board.